

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130123
Date 2021-September-01

Issued to: VIEGA L L C
585 Interlocken Blvd
Broomfield CO, 80021 US

**This is to certify that
representative samples of**

FITTINGS, RUBBER GASKETED
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/CAN/UL 213-Standard for Safety for Rubber
Gasketed Fittings for Fire Protection Service

ANSI/UL 852-Standard for Safety for Metallic Sprinkler Pipe
for Fire Protection Service

ULC/ORD-C199S-94-The Other Recognized Document for
Light Wall steel Pipes for Sprinkler Systems for Fire
Protection Service

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130123
Date 2021-September-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

USL, CNL Rubber gasketed fittings of the following types, sizes and rated pressures:

Press Fittings

MegaPress rubber gasketed fittings in the following types, sizes and rated pressures are intended for use with Schedule 10 and Schedule 40 steel sprinkler pipe and are to be installed with a Viega approved Electro-Hydraulic Press Tool in accordance with the manufacturer's installation instructions.

Model	Type	Size (in.)	Rated Pressure (psig)	Rated Pressure (kPa)
4856	Cap (P)	1, 1-1/4, 1-1/2, 2	175	1210
4856	Cap (P)	2-1/2, 3, 4	175	1210
4815	Coupling (P x P)	1, 1-1/4, 1-1/2, 2	175	1210
4815	Coupling w/ stop (P X P)	2-1/2, 3, 4	175	1210
4815.5	Extended Coupling w/ No stop (PxP)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
4815.5	Coupling w/ No stop	2-1/2, 3, 4	175	1210
4816	90 Degree Elbow (P x P)	1, 1-1/4, 1-1/2, 2	175	1210
4816	90 Degree Elbow (P x P)	2-1/2, 3, 4	175	1210
4816.1	90 Degree Street Elbow (P x FTG)	2-1/2, 3, 4	175	1210



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
 Report Reference EX6157-20130123
 Date 2021-September-01

4826	45 Degree Elbow (P x P)	1, 1-1/4, 1-1/2, 2	175	1210
4826	45° Elbow (P X P)	2-1/2, 3, 4	175	1210
4826.1	45° Street Elbow (P X FTG)	2-1/2, 3, 4	175	1210
4818	Tee (P x P x P)	1, 1-1/4, 1-1/2, 2	175	1210
4818	Tee (P X P X P)	2-1/2, 3, 4	175	1210

Model	Type	Size (in.)	Rated Pressure (psig)	Rated Pressure (kPa)
4815.2	Reducer (P x P)	3/4x1/2; 1x1/2, 1x3/4; 1-1/4x3/4, 1-1/4x1; 1-1/2x1-1/4; 2x1-1/4, 2x1-1/2	175	1210
4815.1	Reducer (FTG X P)	2-1/2 x 1, 2-1/2 x 1-1/4, 2-1/2 x 1-1/2, 2-1/2 x 2; 3 x 1-1/4, 3 x 1-1/2, 3 x 2, 3 x 2-1/2; 4 x 1-1/2, 4 x 2, 4 x 2-1/2, 4 x 3	175	1210
4818	Reducing Tee (P x P x P)	1-1/2 x 1-1/2 x 1, 1-1/2 x 1-1/2 x 1-1/4; 2 x 2 x 1, 2 x 2 x 1-1/4, 2 x 2 x 1-1/2; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4	175	1210
4818	Reducing Tee (P X P X P)	2-1/2 x 2-1/2 x 1-1/2, 2-1/2 x 2-1/2 x 2; 3 x 3 x 1-1/4, 3 x 3 x 1-1/2, 3 x 3 x 2, 3 x 3 x 2-1/2; 4 x 4 x 1-1/2, 4 x 4 x 2, 4 x 4 x 2-1/2, 4 x 4 x 3	175	1210



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
 Report Reference EX6157-20130123
 Date 2021-September-01

4817.2	Reducing Tee (P x P x NPT)	1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1, 1-1/2 x 1-1/2 x 1-1/4; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1, 2 x 2 x 1-1/4, 2 x 2 x 1-1/2	175	1210
4817.2	Female Reducing Tee (PxPxFNPT)	1-1/4x1-1/4x3/4, 1	175	1210
4817.2	Female Reducing Tee (P x P x FNPT)	2-1/2 X 2-1/2 X 3/4; 3 X 3 X 3/4; 4 X 4 X 3/4	175	1210
4860	Union (P x P)	1, 1-1/4, 2	175	1210
4859.5	Flange Adapter (P x F)	1, 1-1/4, 1-1/2, 2	175	1210
4811	Male Adapter (P x MNPT)	1, 1-1/4, 1-1/2, 2	175	1210
4812	Female Adapter (P x FNPT)	1 x 1/2, 1 x 3/4, 1 x 1; 1-1/4 x 1/2, 1-1/4 x 3/4, 1-1/4 x 1, 1-1/4 x 1-1/4; 1-1/2 x 1/2, 1-1/2 x 3/4, 1-1/2 x 1, 1-1/2 x 1-1/4, 1-1/2 x 1-1/2; 2 x 1/2, 2 x 3/4, 2 x 1, 2 x 1-1/4, 2 x 1-1/2, 2 x 2	175	1210
4812	Female Adapter (P X FNPT)	2-1/2, 3, 4	175	1210

Note: Models 4856, 4815, 4816, 4826, 4818, 4860 and 4859.5 in the 1 inch and Model 4818 in the 1-1/2 x 1-1/2 x 1 and 3 x 3 x 1 inch sizes are Listed for use with Sch 40 steel sprinkler pipe only.

MegaPress FKM rubber gasketed fittings in the following types, sizes and rated pressures are intended for use with Schedule 10 and Schedule 40 steel sprinkler pipe and are to be installed with a Viega approved Electro-Hydraulic Press Tool in accordance with the manufacturer's installation instructions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
 Report Reference EX6157-20130123
 Date 2021-September-01

Model	Type	Size, in.	Rated Pressure	
			Psig	kPa
5911	Male Adapter w/FKM (P x MNPT)	1/2 x 1/2, 3/4 x 3/4, 1 x 1, 1-1/4 x 1-1/4, 1-1/2 x 1-1/2, 2 x 2	175	1210
5912	Female Adapter w/FKM (P x FNPT)	1/2 x 1/2; 3/4 x 1/2, 3/4 x 3/4; 1 x 1/2, 1 x 3/4, 1 x 1; 1-1/4 x 1/2, 1-1/4 x 3/4, 1-1/4 x 1, 1-1/4 x 1-1/4 ; 1-1/2 x 1/2, 1-1/2 x 3/4, 1-1/2 x 1, 1-1/2 x 1-1/4, 1-1/2 x 1-1/2 2 x 3/4, 2 x 1, 2 x 1-1/2, 2 x 2	175	1210
5915	Coupling w/Stop w/FKM (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5915.1	Reducer w/FKM (FTG x P)	3/4 x 1/2; 1 x 1/2, 1 x 3/4; 1-1/4 x 3/4, 1-1/4 x 1; 1-1/2 x 3/4, 1-1/2 x 1, 1-1/2 x 1-1/4; 2 x 1, 2 x 1-1/4, 2 x 1-1/2	175	1210
5915.5	Coupling w/No Stop w/FKM (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5916	90° Elbow w/FKM (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5916.1	90° Elbow w/FKM (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
 Report Reference EX6157-20130123
 Date 2021-September-01

Model	Type	Size, in.	Rated Pressure	
			Psig	kPa
5917.2	Female Reducing Tee w/FKM (P x P x FNPT)	3/4 x 3/4 x 1/2, 3/4 x 3/4 x 3/4; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1	175	1210
5918	Tee w/FKM (P x P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5918	Reducing Tee w/FKM (P x P x P)	3/4 x 3/4 x 1/2; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1, 1-1/2 x 1-1/2 x 1-1/4; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1, 2 x 2 x 1-1/4, 2 x 2 x 1-1/2	175	1210
5926	45° Elbow w/FKM (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5926.1	45° Elbow w/FKM (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5956	Cap w/FKM (P x Cap)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210
5959.5	Flange w/FKM (P x Flange)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130123
Date 2021-September-01

Model	Type	Size, in.	Rated Pressure	
			Psig	kPa
5960	Union w/FKM (P x Union)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1210

All model MegaPress rubber gasketed fittings are suitable for use in dry pipe systems for temperatures to -40 degree F.

P – Press

F – Flange

FTG – Plain End Fitting

FNPT – Female NPT Threads

MNPT – Male NPT Threads

10 refers to Schedule 10 steel sprinkler pipe in accordance with NFPA 13.

40 refers to Schedule 40 steel sprinkler pipe in accordance with NFPA 13.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

