



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-7301BS0375**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
<b>Distributor</b> <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
<b>Product Category</b> <i>Produktart</i>	stainless tubes: stainless steel tube (7301)
<b>Product Description</b> <i>Produktbezeichnung</i>	stainless steel tube for drinking water installation according to DVGW-working sheet GW 541
<b>Model</b> <i>Modell</i>	Sanpress Rohr 1.4521
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 120000430-19 from 09.10.2019 (MPM) mechanical test: 120000430-09 from 09.10.2009 (MPM) mechanical test: 120002789-3 from 16.05.2007 (MPM) type testing: 120002790-3 from 25.07.2007 (MPM)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004) UBA METALLE (14.05.2020)

Z1200104A-DE

**Date of Expiry / File No.** 25.07.2025 / 21-0709-WNU  
**Ablaufdatum / Aktenzeichen**

02.09.2021 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle  
Josef-Wirmer-Str. 1-3  
53123 Bonn  
Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993  
www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Sanpress Rohr 1.4521	manufacturing group: 12,0 up to 108,0 mm	according to GW 541, table 3

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

tested dimensions according to GW 541, Tabelle 3: 12,0 mm, 15,0 mm, 18,0 mm, 22,0 mm, 28,0 mm, 35,0 mm, 42,0 mm, 54,0 mm, 64,0 mm, 76,1 mm, 88,9 mm and 108,0 mm

DVGW